

Page 1 of 20
Permit No.: ST-9216
Issuance Date: January 28, 2005
Effective Date: April 1, 2005
Expiration Date: March 31, 2010

STATE WASTE DISCHARGE PERMIT NO. ST-9216

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY
CENTRAL REGIONAL OFFICE

In compliance with the provisions of the
State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington, as amended,
and
the Federal Water Pollution Control Act
(The Clean Water Act)
Title 33 United States Code, Section 1251 et seq.,
authorizes

YAKIMA CHIEF, INC.
PO BOX 209
SUNNYSIDE, WA 98944

to discharge wastewater in accordance with the special and general conditions which follow.

<u>Facility Address:</u> 555 W. South Hill Road Sunnyside, WA 98944	<u>Discharge Location to the Port of Sunnyside IWWTF</u> Latitude: 46° 18' 26" N Longitude: 120° 01' 52" W <u>Land Application: Landscape Irrigation & Dust Abatement</u> Parcel Number 221035-42017 SE corner of the SW corner of Sec. 35, T9N, R23E, W.M.
<u>Industrial Wastewater Treatment Facility (IWWTF) Receiving Discharge:</u> Port of Sunnyside	
<u>Industry Type:</u> Production of Hop Extracts	<u>SIC Code:</u> 2087

G. Thomas Tebb, L.E.G.
Section Manager
Water Quality Program
Central Region Office
Washington State Department of Ecology

TABLE OF CONTENTS

	<u>Page</u>
SUMMARY OF PERMIT REPORT SUBMITTALS.....	4
SPECIAL CONDITIONS.....	5
S1. DISCHARGE LIMITATIONS	5
A. Discharges to the IWWTF	5
B. Discharges to the Infiltration /Evaporation Pond.....	5
C. Land Application.....	6
S2. MONITORING REQUIREMENTS	7
A. Wastewater Monitoring.....	7
1. Discharges to the IWWTF	7
2. Discharges to the Percolation/Evaporation Pond.....	7
3. Discharges to Irrigation and Dust Abatement.....	8
B. Sampling and Analytical Procedures	8
C. Flow Measurement.....	8
D. Laboratory Accreditation	9
E. Request for Reduction in Monitoring	9
S3. REPORTING AND RECORDKEEPING REQUIREMENTS	9
A. Reporting.....	9
B. Records Retention	10
C. Recording of Results	10
D. Additional Monitoring by the Permittee	10
E. Noncompliance Notification	10
F. Dangerous Waste Discharge Notification.....	11
G. Spill Notification.....	11
H. Maintaining a Copy of This Permit.....	11
I. Request for Reduction in Monitoring	11
S4. OPERATION AND MAINTENANCE (O&M).....	12
A. O&M Manual	12
B. Bypass Procedures	12
S5. PROHIBITED DISCHARGES.....	14
A. General Prohibitions	14
B. Specific Prohibitions	14
C. Prohibited Unless Approved	15
S6. DILUTION PROHIBITED.....	15
S7. SOLID WASTE DISPOSAL	15
A. Solid Waste Handling	15
B. Leachate	15
C. Solid Waste Control Plan	16
S8. SPILL AND SLUG DISCHARGE PREVENTION AND CONTROL PLAN.....	16

S9.	SAMPLING AND ANALYSIS PLAN	16
GENERAL CONDITIONS		17
G1.	SIGNATORY REQUIREMENTS.....	17
G2.	RIGHT OF ENTRY	17
G3.	PERMIT ACTIONS.....	18
G4.	REPORTING A CAUSE FOR MODIFICATION	18
G5.	PLAN REVIEW REQUIRED	18
G6.	COMPLIANCE WITH OTHER LAWS AND STATUTES	19
G7.	DUTY TO REAPPLY	19
G8.	PERMIT TRANSFER.....	19
G9.	REDUCED PRODUCTION FOR COMPLIANCE	19
G10.	REMOVED SUBSTANCES	20
G11.	PAYMENT OF FEES	20
G12.	PENALTIES FOR VIOLATING PERMIT CONDITIONS.....	20

SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S3.A.	Discharge Monitoring Report	Quarterly	July 15, 2005^a
S4.A.	O&M Manual Update	1/permit cycle	January 31, 2006
S4.A.	Update O&M Manual Appendix A	Annually	As needed
S7.C.	Solid Waste Control Plan Update or Review	Annually	As needed
S8.	Spill and Slug Discharge Prevention and Control Plan Update or Certification	1/permit cycle	March 31, 2009
S9.	Sampling and Analysis Plan	1/permit cycle	April 30, 2005
G1.	Signature Authorization/Delegation	as needed	as needed
G7.	Application for permit renewal	1/permit cycle	March 31, 2009^b

^a DMRs submitted quarterly on January 15, April 15, July 15, and October 15

^b At least one (1) year prior to permit expiration date

SPECIAL CONDITIONS

S1. DISCHARGE LIMITATIONS

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a concentration in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit.

A. Discharges to the IWWTF

Beginning **April 1, 2005** and lasting through **March 31, 2010**, the discharge from this facility is subject to limitations established by contract between the facility and the Port of Sunnyside. At the time of issuance the contract dated June 28, 2000 is in effect. The effluent limitations in that contract constitute the enforceable limits of this permit. The limits are located in Appendix A of the O&M Manual.

The Department anticipates that the facility and the Port of Sunnyside may renegotiate the contract during the course of this permit as more information is generated on the variability of the discharge and the Port's treatment capacity. Upon establishment of a new contract, the facility shall submit the contract to the Department for approval. Upon approval the contract will be incorporated into the O&M Manual as a replacement Appendix A, and the limitations established in the new contract will become the enforceable limits of this permit.

In addition, pH of the discharge shall be within the range of 5-11 at all times.

B. Discharges to the Infiltration /Evaporation Pond

Beginning on **April 1, 2005** and lasting through **March 31,, 2010**, the Permittee is authorized to discharge wastewater to infiltration pond, at the permitted location subject to the following limitations:

EFFLUENT LIMITATIONS	
Parameter	Maximum Daily ^a
Pond Capacity	Not to exceed capacity of 0.224 million gallons
TDS	500 mg/l
pH	Between 6.5 and 8.5 at all times
^a The maximum daily effluent limitation is defined as the highest allowable discharge during a calendar day.	

C. Land Application

Land application shall follow the Irrigation Best Management Practices as described below:

1. There shall be no runoff of wastewater applied to land by spray irrigation to any surface waters of the State or to any land not owned by or under control of the Permittee.
2. The Permittee shall use recognized good practices, and all available and reasonable procedures to control odors from the land application system. When notified by the Department, the Permittee shall implement measures to reduce odors to a reasonable minimum.
3. The wastewater shall not be applied to the irrigation lands in quantities that:
 - a. Significantly reduce or destroy the long-term infiltration rate of the soil.
 - b. Would cause long-term anaerobic conditions in the soil.
 - c. Would cause ponding of wastewater, produce objectionable odors, or support insects or vectors.
 - d. Would cause leaching losses of constituents of concern beyond the treatment zone or in excess of the approved design. Constituents of concern are constituents in the wastewater, partial decomposition products, or soil constituents that would alter ground water quality in amounts that would affect current and future beneficial uses.
4. The Permittee shall maintain all irrigation agreements for lands not owned for the duration of the permit cycle. Any reduction in irrigation lands by termination of any irrigation agreements may result in permit modification or revocation. The Permittee shall immediately inform the Department in writing of any proposed changes to existing agreements.

S2. MONITORING REQUIREMENTS

A. Wastewater Monitoring

1. Discharges to the IWWTF

The Permittee shall monitor the wastewater according to the following schedule:

Parameter	Units	Sample Point	Sampling Frequency	Sample Type
Flow	Total gallons/month	weir	Continuous	Meter
pH	Standard Units	a	Weekly	Composite
TSS	lbs./month	a	Monthly	Composite
COD	lbs./month	a	Monthly	Composite
TDS	lbs./month	a	Monthly	Composite
FDS	lbs./month	a	Monthly	Composite

a- Sampling point is at the auto-sampler in the manhole at the south end of the property.

2. Discharges to the Percolation/Evaporation Pond

Monitoring shall be conducted in accordance with the following schedule. In the event the Permittee does not discharge “no discharge” shall be written on the discharge monitoring report and submitted according to schedule.

The monitoring schedule is as follows:

Parameter	Units	Sample Point	Sampling Frequency	Sample Type
Combined Flow ¹	gallons/day	Meter(s)	Daily	Calculation
Water Level	Feet/inches	Pond	Weekly	Measurement
pH	Standard Units	Pond	Weekly	Grab
Specific Conductance	mho/cm @ 25° C	Pond	Weekly	“
TDS	mg/L	Pond	Quarterly	“

¹ Flows to the pond are metered. These flows consist of Chiller water, Seal Flush water and non-contact one pass cooling water from the Packing Line water jackets.

The Department reserves the right to modify the monitoring schedule as further information becomes available.

3. Discharges to Irrigation and Dust Abatement

Irrigation and dust abatement water comes directly from the Percolation/Evaporation Pond which is required to be monitored already therefore, the monitoring schedule is as follows:

Parameter	Units	Sample Point	Sampling Frequency	Sample Type
Flow ¹	gpd	Pump	Daily	Calculation

B. Sampling and Analytical Procedures

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the water and wastewater monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 or to the latest revision of *Standard Methods for the Examination of Water and Wastewater* (APHA), unless otherwise specified in this permit or approved in writing by the Department of Ecology (Department).

C. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements are consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations and at a minimum frequency of at least one calibration per year. Calibration records shall be maintained for at least three (3) years.

D. Laboratory Accreditation

All monitoring data required by the Department shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, Chapter 173-50 WAC. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement.

E. Request for Reduction in Monitoring

The Permittee may request the Department of Ecology (Department) review the data to determine whether a reduction of the sampling frequency is warranted after twenty-four (24) months of monitoring. The request shall: (1) be in written form, (2) clearly state the parameters for which the reduction in monitoring is being requested, and (3) clearly state the justification for the reduction. Any request for reduction in monitoring shall be granted at the Department's discretion and accomplished through an Administrative Order or permit modification.

S3. REPORTING AND RECORDKEEPING REQUIREMENTS

The Permittee shall monitor and report in accordance with the following conditions. The falsification of information submitted to the Department shall constitute a violation of the terms and conditions of this permit.

A. Reporting

The first monitoring period begins on **April 1, 2005**. Monitoring results shall be submitted quarterly on the 15th of January, April, July and October. Monitoring results obtained during the previous three (3) months shall be reported on the monthly forms as provided, or otherwise approved, by the Department. The report shall be sent to:

Permit Data Systems Manager
Department of Ecology
Central Regional Office
15 West Yakima Avenue, Suite 200
Yakima, Washington 98902

Discharge Monitoring Report forms must be submitted quarterly whether or not the facility was discharging. If there was no discharge or the facility was not operating during a given monitoring period, submit the form as required with the words "no discharge" entered in place of the monitoring results.

B. Records Retention

The Permittee shall retain records of all monitoring information for a minimum of three years. Such information shall include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by the Director.

C. Recording of Results

For each measurement or sample taken, the Permittee shall record the following information: (1) the date, exact place, method, and time of sampling; (2) the individual who performed the sampling or measurement; (3) the dates the analyses were performed; (4) who performed the analyses; (5) the analytical techniques or methods used; and (6) the results of all analyses.

D. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by this permit using test procedures specified by Special Condition S2. of this permit, then the results of this monitoring shall be included in calculation and reporting of the data submitted in the Permittee's self-monitoring reports.

E. Noncompliance Notification

In the event the Permittee is unable to comply with any of the permit terms and conditions due to any cause, the Permittee shall:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the violation, and correct the problem;
2. Repeat sampling and analysis of any violation and submit the results to the Department within thirty (30) days after becoming aware of the violation;
3. Immediately notify the Department and the local sewage treatment plant manager of the failure to comply; and

4. Submit a detailed written report to the Department within thirty (30) days (five (5) days for upsets and bypasses), unless requested earlier by the Department. The report should describe the nature of the violation, corrective action taken and/or planned, steps to be taken to prevent a recurrence, results of the resampling, and any other pertinent information.

Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

F. Dangerous Waste Discharge Notification

The Permittee shall notify the IWWTF and the Department in writing of the intent to discharge into the IWWTF any substance designated as a dangerous waste in accordance with the provisions of WAC 173-303-070. This notification shall be made at least ninety (90) days prior to the date that discharge is proposed to be initiated.

G. Spill Notification

The Permittee shall notify the IWWTF immediately (as soon as discovered) of all discharges that could cause problems to the IWWTF, such as process spills and unauthorized discharges (including slug discharges).

H. Maintaining a Copy of This Permit

A copy of this permit shall be kept at the facility and be made available upon request to Ecology inspectors.

I. Request for Reduction in Monitoring

The Permittee may request the Department of Ecology (Department) review the data to determine whether a reduction of the sampling frequency is warranted after twelve (12) months of monitoring. The request shall: (1) be in written form, (2) clearly state the parameters for which the reduction in monitoring is being requested, and (3) clearly state the justification for the reduction. Any request for reduction in monitoring shall be granted at the Department's discretion and accomplished through an Administrative Order or permit modification.

S4. OPERATION AND MAINTENANCE (O&M)

The Permittee shall at all times be responsible for the proper O&M of any facilities or systems of control installed to achieve compliance with the terms and conditions of the permit.

A. O&M Manual

The O&M Manual shall be reviewed by the Permittee at least annually. Substantial changes or updates to the O&M Manual shall be submitted to the Department whenever they are incorporated into the manual.

The Permittee is required to submit for Departmental approval an updated O&M Manual no later than **January 31, 2006**.

The approved Operations and Maintenance Manual shall be kept available at the permitted facility and all operators shall follow the instructions and procedures of this manual.

In addition to the requirements of WAC 173-240-150(1) and (2), the O&M Manual shall include:

1. Plant maintenance procedures;
2. Best management practices for operation and maintenance of the evaporation/infiltration pond;
3. Procedures and protocols for monitoring associated with discharges to the evaporation/infiltration pond, including sampling from monitoring wells, if necessary;
4. O&M of any equipment or procedures utilized by the Permittee to pretreat discharges to the IWWTF, including screens and neutralization; and,
5. Appendix A, containing the current User Contract and Schedule A, detailing the Permittee's hydraulic and organic loading allocations to the IWWTF.

B. Bypass Procedures

The Permittee shall immediately notify the Department and the receiving IWWTF of any spill, overflow, or bypass from any portion of the collection or treatment system.

The bypass of wastes from any portion of the treatment system is prohibited unless one of the following conditions (1, 2, or 3) applies:

1. Unavoidable Bypass—Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.

If the resulting bypass from any portion of the treatment system results in noncompliance with this permit the Permittee shall notify the Department and the receiving IWWTF in accordance with Special Condition S3.E “Noncompliance Notification.”

2. Anticipated Bypass That Has The Potential to Violate Permit Limits or Conditions—Bypass is authorized by an administrative order issued by the Department. The Permittee shall notify the Department and the IWWTF at least thirty (30) days before the planned date of bypass. The notice shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass. The Department will consider the following prior to issuing an administrative order:
 - a. If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of the permit.
 - b. If there are feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
 - c. If the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, the Department will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Approval of a request to bypass will be by administrative order issued by the Department under RCW 90.48.

3. Bypass For Essential Maintenance Without the Potential to Cause Violation of Permit Limits or Conditions -- Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of the permit, a violation of a pretreatment standard or requirement, or adversely impact public health as determined by the Department prior to the bypass.

S5. PROHIBITED DISCHARGES

A. General Prohibitions

The Permittee shall not introduce into the IWWTF pollutant(s) which cause Pass Through or Interference.

B. Specific Prohibitions

In addition, the following shall not be introduced into the IWWTF:

1. Pollutants which create a fire or explosion hazard in the IWWTF, including, but not limited to, waste streams with a closed cup flashpoint of less than 60°C (140°F) using the test methods specified in 40 CFR 261.21.
2. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the IWWTF resulting in interference;
3. Any pollutant, including oxygen demanding pollutants (BOD, etc.), released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the IWWTF;
4. Heat in amounts which will inhibit biological activity in the IWWTF resulting in interference, but in no case heat in such quantities that the temperature at the IWWTF treatment plant exceeds 40°C (104°F) unless the approval authority, upon request of the IWWTF, approves alternative temperature limits;
5. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
6. Pollutants which result in the presence of toxic gases, vapors, or fumes within the IWWTF in a quantity that may cause acute worker health and safety problems;
7. Any trucked or hauled pollutants, except at discharge points designated by the IWWTF.
8. Pollutants which will cause corrosive structural damage to the IWWTF,

C. Prohibited Unless Approved

1. Any of the following discharges are prohibited unless approved by the Department under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or a need to augment sewage flows due to septic conditions):
 - a. Noncontact cooling water in significant volumes.
 - b. Storm water and other direct inflow sources.
 - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment or would not be afforded a significant degree of treatment by the system.
2. Unless specifically authorized in this permit, the discharge of dangerous wastes as defined in Chapter 173-303 WAC, is prohibited.

S6. DILUTION PROHIBITED

The Permittee shall not dilute the wastewater discharge with stormwater or increase the use of potable water, process water, noncontact cooling water, or, in any way, attempt to dilute an effluent as a partial or complete substitute for adequate treatment to achieve compliance with the limitations contained in this permit.

S7. SOLID WASTE DISPOSAL

A. Solid Waste Handling

The Permittee shall handle and dispose of all solid waste material in such a manner as to prevent its entry into State ground water, surface water or IWWTF.

B. Leachate

The Permittee shall not allow leachate from its solid waste material to enter State waters without providing all known, available and reasonable methods of prevention, control and treatment (AKART), nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee shall apply for a permit or permit modification as may be required for such discharges to State ground or surface waters.

C. Solid Waste Control Plan

Under authority of RCW 90.48.080, the Permittee has developed and submitted to the Department and the Jurisdictional Health Department, a Solid Waste Plan to prevent solid waste from causing pollution of waters of the state. This plan includes all solid wastes with the exception of those solid wastes regulated by Chapter 173-303 WAC (Dangerous Waste Regulations). The plan meets the rule requirements of Chapter 173-350 WAC.

The plan shall include at a minimum: a description, source, generation rate, and disposal methods of these solid wastes. The plan shall identify specific individuals who are responsible for said plan and a means to contact them during normal hours of business. This plan shall not be at variance with any approved local solid waste management plan. Any proposed revision or modification of the solid waste handling plan must be submitted to the Department. The Permittee shall comply with the plan and any modifications thereof. This plan shall be reviewed annually or updated as conditions change, whichever is more frequent.

S8. SPILL AND SLUG DISCHARGE PREVENTION AND CONTROL PLAN

The current approved plan shall be maintained on the plant site and be readily available to facility personnel. The Permittee shall submit an update of the Spill and Slug Discharge Prevention and Control Plan, or a certification that it is current with the application for permit renewal.

S9. SAMPLING AND ANALYSIS PLAN

The Permittee shall submit to the Department, for review and approval, a Sampling and Analysis Plan no later than **April 30, 2005**. The Plan shall address all surfaces and irrigation water monitoring required in this permit. Upon Departmental approval the Plan shall be placed in Appendix B of the updated O & M Manual. Appendix B shall then supplant the monitoring requirements in Special Conditions, S2.B., and constitute the enforceable monitoring requirements of the permit. The Plan shall include the following elements, which are based in accordance with *Guidelines for Preparing Quality Assurance Project Plans for Environmental Studies*, 2004, Ecology Publ. No. 04-03-030:

- Area description
- Organization and scheduling
- Sampling procedures
- Measurement procedures
- Quality control
- Data management

GENERAL CONDITIONS

G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to the Department shall be signed as follows:

- A. All permit applications shall be signed by either a principal executive officer or ranking elected official.
- B. All reports required by this permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by the person described above and is submitted to the Department at the time of authorization, and
 - 2. The authorization specifies either a named individual or any individual occupying a named position.
- C. Changes to authorization. If an authorization under paragraph B.2. above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

G2. RIGHT OF ENTRY

Representatives of the Department shall have the right to enter at all reasonable times in or upon any property, public or private, for the purpose of inspecting and investigating conditions relating to the pollution or the possible pollution of any waters of the State.

Reasonable times shall include normal business hours; hours during which production, treatment, or discharge occurs; or times when the Department suspects a violation requiring immediate inspection. Representatives of the Department shall be allowed to have access to, and copy at reasonable cost, any records required to be kept under terms and conditions of the permit; to inspect any monitoring equipment or method required in the permit; and to sample the discharge, waste treatment processes, or internal waste streams.

G3. PERMIT ACTIONS

This permit shall be subject to modification, suspension, or termination, in whole or in part by the Department for any of the following causes:

- A. Violation of any permit term or condition;
- B. Obtaining a permit by misrepresentation or failure to disclose all relevant facts;
- C. A material change in quantity or type of waste disposal;
- D. A material change in the condition of the waters of the State; or
- E. Nonpayment of fees assessed pursuant to RCW 90.48.465.

The Department may also modify this permit, including the schedule of compliance or other conditions, if it determines good and valid cause exists, including promulgation or revisions of regulations or new information.

G4. REPORTING A CAUSE FOR MODIFICATION

The Permittee shall submit a new application, or a supplement to the previous application, along with required engineering plans and reports, whenever a new or increased discharge or change in the nature of the discharge is anticipated which is not specifically authorized by this permit. This application shall be submitted at least sixty (60) days prior to any proposed changes. Submission of this application does not relieve the Permittee of the duty to comply with the existing permit until it is modified or reissued.

G5. PLAN REVIEW REQUIRED

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to the Department for approval in accordance with Chapter 173-240 WAC. Engineering reports, plans, and specifications should be submitted at least one hundred eighty (180) days prior to the planned start of

construction. Facilities shall be constructed and operated in accordance with the approved plans.

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES

Nothing in the permit shall be construed as excusing the Permittee from compliance with any applicable Federal, State, or local statutes, ordinances, or regulations.

G7. DUTY TO REAPPLY

The Permittee must apply for permit renewal at least one (1) prior to the specified expiration date of this permit.

G8. PERMIT TRANSFER

This permit is automatically transferred to a new owner or operator if:

- A. A written agreement between the old and new owner or operator containing a specific date for transfer of permit responsibility, coverage, and liability is submitted to the Department;
- B. A copy of the permit is provided to the new owner and the receiving IWWTF is notified and;
- C. The Department does not notify the Permittee of the need to modify the permit.

Unless this permit is automatically transferred according to section A. above, this permit may be transferred only if it is modified to identify the new Permittee and to incorporate such other requirements as determined necessary by the Department.

G9. REDUCED PRODUCTION FOR COMPLIANCE

The Permittee shall control production or discharge to the extent necessary to maintain compliance with the terms and conditions of this permit upon reduction of efficiency, loss, or failure of its treatment facility until the treatment capacity is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power for the treatment facility is reduced, lost, or fails.

G10. REMOVED SUBSTANCES

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the effluent stream for discharge.

G11. PAYMENT OF FEES

The Permittee shall submit payment of fees associated with this permit as assessed by the Department. The Department may revoke this permit if the permit fees established under Chapter 173-224 WAC are not paid.

G12. PENALTIES FOR VIOLATING PERMIT CONDITIONS

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be and be deemed to be a separate and distinct violation.